DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: LK Norman Properties APPLICANT: _____ DATE EVALUATED: 8/14/98
ADDRESS: _____ APPLICATION DATE: _____ PROPERTY SIZE: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY RECORDED: _____
LOCATION OF SITE: Harborwatch 5 Lot #112
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	10%	0-9"	Brw SaL GR FR		SS,SR,SE,FR w/ Trcls of SAP				PS .3
		9-15	Rd/Brw C/L SBK SS						
2	18%	0-8	Brw SaL GR FR		SS,SR SE,FR SS,SP SE,FR of SAP			w/Trcls	PS .3
		8-28	Rd/Brw C/L M SBK						
		28-45	Rd/Brw C/L w SBK S						
3	15%	0-30"	Rd/Brw C/L w FR		SAP; Rd F w/ Trcls				PS SAP .3
		30-44	Rd/Brw C/L w SBK S						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____