IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Troy Cashadden DATE 7-30-71 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd - Across from Martin's Trading Post


S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area 20,000

Character & Porosity of Soil Clay loam
Percolation Rate non taken
Topography slope to river
Depth to Water Table —
Rock or other impervious formations none observed



Plot of System

Size of Tank 1,000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY /

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Conway DATE 7-30-71

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold