DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 2 OF 2

PROPERTY I.D.#:
DATE:
COUNTY:

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Linda Ritchie
OWNER__AGENT__PHONE:
ADDRESS:
APPLICATION DATE:__DATE EVALUATED
PROPOSED FACILITY:
PROPERTY SIZE:

LOCATION OF SITE:
WATER SUPPLY: On-site Well___Comm. Well___Public___Other___EVAL METHOD: Auger Boring__Pit___Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1)(1) TEXTURE	.1941 (1)(2) STRUCTURE	.1941 (1)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
5		0-4"	cl	gr	1:1 / fr			.1942 Wetness Cond. - S
	14-16%	4"-32"	c	sBk	1:1 / fr			.1943 Depth/.1956 Sapr. - 45" P.S.
	L	32"-45"	c/sap	5bk/m	1:1 / fr			.1944 Restrictive Hori. - NA
		45"-48"	Sap	m	1:1 / fr			.1948 Profile Class. - P.S.
								Profile LTAR - .3
6	12-14%	0-3"	cl	gr	1:1 / fr			.1942 Wetness Cond. - U
	L	3"-37"	c	Abk	1:1/fr/s,p	clay was	wet.	.1943 Depth/.1956 Sapr. -
		37"-40"	c/sap.	Abk/m	1:1/fr/s,p	clay was	wet.	.1944 Restrictive Hori. -
		40"-48"	Sap	m	1:1 /fr.			.1948 Profile Class. - U
								Profile LTAR -
7	16%	0-5"	cl	gr	1:1 / fr /			.1942 Wetness Cond. - U
	L	5"-36"	c	Abk	1:1 / fr / s,p	clay was	wet	.1943 Depth/.1956 Sapr. -
		36"-44"	c/sap	Abk/m	1:1 / fr / s,p	clay was	wet	.1944 Restrictive Hori. -
		44"-48"	Sap	m	1:1 / fr /			.1948 Profile Class. - U
								Profile LTAR -
8	14-16%	0-5"	cl					.1942 Wetness Cond. - S
	L	5"-39";	c					.1943 Depth/.1956 Sapr. - 45" P.S.
		39"-45"	c/sap					.1944 Restrictive Hori. - NA
		45"-48"	sap.					.1948 Profile Class. - P.S.
2-2-95								Profile LTAR - .3

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946)___SITE CLASSIFICATION (.1948) P.S.
SYSTEM TYPE conventional, gravity fed LONG-TERM ACCEPTANCE RATE(S) .3gpd/ft²
EVALUATED BY: Michael Denmon OTHER(S) PRESENT: Linda Ritchie
COMMENTS:

0016600