
Approved 3 Bedroom

Customer LEE 28 x 76

Acknowledgement Of
Plans Submittal ONLY!
Date 12.12.07
Date 12/2/07



APPROVED
SEP 2 9 2004
REVIEWED BY: S. FRANCIS
HWCNC, P.C.

ELECTRICAL SCHEDULE

NOMENCLATURE	CIRCUIT #	VOLTS	WIRE	BREAKER
RECEPT.	1,3,5,7	120	14-2	15-SP
LIGHT	2,4	120	14-2	15-SP AFCI
KITCHEN	25,26	120	12-2	20-SP
DINING ROOM	6	120	12-2	20-SP
BATH GFI	8	120	14-2	15-SP
WASHER	11	120	12-2	20-SP

NOMENCLATURE	CIRCUIT #	VOLTS	WIRE	BREAKER
DRYER	17,19	240	10-3	30-DP
WATER HEATER	10,12	240	10-2	25-DP
RANGE	22,24	220	8-3	40-DP
FURNACE	14,16 18,20	240 240	6 REM 10 Nm-B	60-2SP 30-DP
OPT. D/WASH	21	120	14-2	15-SP
OPT. G/DISP	15	120	14-2	15-SP
OPT. SPA OR WP, GB JAC	23	120	12-2	20-SP/GFI

NOMENCLATURE	CIRCUIT #	VOLTS	WIRE	BREAKER
SMOKE DETECTOR	9	120	14-3	15-SP
RANGE HOOD / OPT. MICROWAVE	13	120	14-2	15-SP

(S) SMOKE DETECTOR
(D) DUPLEX RECEPTACLE 120 V.
(R) SINGLE RECEPTACLE 240 V.
INCANDESCENT LIGHT WITH 1- 60 W. BULB
VENT FAN
COMB. VENT FAN & LIGHT

SYMBOLS

- DISHWASHER
- THERMOSTAT
- FLUORESCENT FIXTURE WITH 2- 40W TUBES
- EXIT SIGNS
- JUNCTION BOX (NON POWERED UNLESS CIRCUIT NO. IS SHOWN)
- TELEPHONE JACK
- SUPPLY AIR REGISTER
- RETURN AIR REGISTER
- FLOOD LIGHT 2-150W BULBS
- SWITCH & 3 WAY SWITCH
- EMERGENCY LIGHT WITH BATTERY BACKUP
- GARBAGE DISPOSAL

CLAYTON HOMES - RICHFIELD
44073 HWY. 52 N. RICHFIELD, NC 28137

DATE: 14 SEPT 04
THIRD PARTY:
CODES: SEE NOTES
STATE LABEL(S): NC
REVISIONS:
BY: JTH
SCALE: 3/16" = 1'-0"

RESIDENTIAL MOD.

ELECTRICAL

DRAWING #	Model #	JOB NO.
721N	MNJA724A	1866-2784

SHEET 5 OF 15