IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Walter Kiser DATE 9/16/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 S, T.R. on old NK Rd, T.L. on Buffalo Shoals Rd, go 2.8 mile, MH on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	( )	No	(✓)	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 100 x 200


Character & Porosity of Soil Red Clay

Percolation Rate none

Topography 2-6%

Depth to Water Table 6'+

Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Glen Osteroth

IMPROVEMENTS PERMIT BY _____

COMMENTS: System inspected in adverse weather

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 9/16/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold