IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Aldridge DATE Aug. 31, 77 PERMIT NO. _____

PHONE: Business 872-5235 Home 873-8566

LOCATION Buffalo Shoals rd. to rd. 1437 TL, then TL out 1st rd. to left, trailer on left. S. R. No. _____

SUBDIVISION NAME Buffalo Park LOT NO. 41-42 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 +


Character & Porosity of Soil red clay

Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Existing

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Henry Sigmond

IMPROVEMENTS PERMIT BY _____

COMMENTS: System functioning properly – no surfacing at present time; if malfunctions in future, must be repaired to meet Iredell Co. regulations.

CERTIFICATE OF COMPLETION BY Carley B. Powell DATE Aug. 31, 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold