IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

R OR CONTRACTOR JOE LINGLE DATE 1-27-81 PERMIT NO.

E: Business Home

TION Buffalo Shoals Rd. go 2.8 miles past Kyles X rds. house on left

S. R. No.

VISION NAME LOT NO. SECTION OR BLOCK NO.


(✓) Mobile Home ( ) Business ( ) Other mowing house onto property

drooms 3 No. Bathrooms 1 ✓
ge Disposal Unit Yes ( ) No (✓)
Dishwasher Yes ( ) No (✓)
Wash. Machine Yes (✓) No ( )
itable Yes (✓) No ( )

Character & Porosity of Soil Clay fine sandy clay
Percolation Rate slegd pg ft.
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

ea Iscreenproof.

Basement with Plumbing ____ Basement without Plumbing ____ No Basement ✓



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Roger Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

OVEMENTS PERMIT BY Andrew E. Carney

MENTS:

The proposed pole shed addition does not appear to impact the existing septic system.
**NOTE:
R.S.
Date:
ICHD-Environmental Health Division

IFICATE OF COMPLETION BY Steve Bro DATE 1-27-81

TING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS
is VOID if any unauthorized changes are made in installation of system and or if any false information is supplied in obtaining
ovements Permit.

JAN. 1, 1989 7:23