IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Feimster DATE 1-28-75 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Buffalo Shoals Road. Beyond E. Mombo Road
House on L. at Road # 1490 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 130 X 200

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke
R. E. Tony

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts & all surface water should be diverted away from tank & line

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 1-28-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold