DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Chris Davidson APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-31-97
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: _____
LOCATION OF SITE: Buffalo Shoals comm. PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

lot 12

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4-10% LA	0-18	wSBk SCL	Fr SS SP	N/A	48"	N/A	N/A	0.32
		18-48	wSBk C/SC	Fr SS SP					
2	8-10	0-6	wSBk SCL	Fr SS SP	N/A	48"	N/A	N/A	0.3
		6-48	wm SBk C	Fi/Fr SS SP					
3	5-6	0-12	Gr SL	VFr SS SP	NA	48	N/A	N/A	0.3
		12-36	SBk C	Fr/Fi SS SP					
		36-48	wSBk C/CL	Fr SS SP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____