DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Chris Davidson APPLICANT: _____ 5-31-77
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: Bank PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: _____
LOCATION OF SITE: Buffalo Shoals comm. PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

1 of 11

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	~~Ft~~ 5-8%	0-4	Gr SL	VFr ~~SS~~	N/A	48"	N/A	N/A	0.3 0.32
		4-12	Gr/wSBk SCL	Fr SS SP					
		12-48	mSBk C/SC	Fi/F SS SP					
2		0-4	Gr SC	Fr ~~SS~~	N/A	48"	N/A	N/A	0.3 .32
		4-12	wSBk SC	Fr/ SS SP					
		12-48	mSBk C	Fi SS SP					
3		0-12							0.3
		12-36							
		36-48							
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____