13427.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TROY CASKADDON DATE 10-2-91 PERMIT NO. 36-A-9-4B, 6

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. west past Pinesville Rd. - T.R. on dirt st. at Fellowship Bapt. Church - go around curve & 300 yards on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 6 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other MAY BUILD 3 BEDR. HOUSE LATER.

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3.36 acres.

Character & Porosity of Soil Prov. Suitable.


Percolation Rate 4 gal./sq. ft.

Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 400 Linear Ft. 300

Depth of Stone in Lines 12

Water Supply: Individual (✓)

Public ( )

Installed by Mike Holland

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 10-2-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold