13132.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR EDWARD C. HIOTT DATE 7-23-91 PERMIT NO 304-B-2.

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. past Pinesville Rd - T.R. at Fellowship Bapt. Church bear left at forks - go 1/8 mi. T.R. on 5th drive - Doublewide 400 ft. on left.

SUBDIVISION NAME TROUTMAN TRACE DEV. LOT NO. 2. SECTION OR BLOCK NO. 1st.


House ( ) Mobile Home (✓) Business ( ) Other _____ DOUBLEWIDE

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev. Suitable.	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	2-6 gal/sq.ft.	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+	
			Rock or other impervious formations	none observed.	

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Chaffin Farms

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-23-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold