DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Pg 2 of 2 PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: PATSY Ray Trantham APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 6-29-99
PROPOSED FACILITY: SFDwlg PROPOSED DESIGN FLOW (.1949): 2K PROPERTY SIZE: .55
LOCATION OF SITE: Lot 7 Harold Lane off Bethel Church Rd PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
PIT 1	L		SBKW C	VFI					PS .2 AT 36" .25@48"
			SBKW C SaPl/Mod						
PIT 2			SBKmod C	VFI					PS 12
PIT 3	H		SBKmod C	VFI	Yellow/RS 18" Gray Red Gray White 24"				U
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	.3	.2

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J. Cotton
OTHER(S) PRESENT: Jack Moore