No. 03413

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

1 pm.

OWNER OR CONTRACTOR William A. Ladd DATE 9/19/85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shls. rd. West - 80 1/4 mi. past Pinewille Rd. - TR) into dev. - 80 to forks - TL. - 200 yds. on Right (back) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil _____
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate _____
Auto. Wash. Machine	Yes (✓)	No ( )	Topography _____
Site Suitable	Yes (✓)	No ( )	Depth to Water Table _____
			Rock or other impervious formations _____

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12

Water Supply: Individual (✓)
Public ( )

Installed by Chapin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Bobby D. Smith DATE 4/19/85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold