DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Chris Davidson APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10/12/01
PROPOSED FACILITY: 3BR House/Lot PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.70 Ac.
LOCATION OF SITE: Lot # 3 Pinevile Rd. PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	5% Chea.	0-2	SL	NS NP VFR					PS .35
		2-13	SCL wbk	fr SS SP SE-P					
		13-25	CL mdbk	FM SS SP SE-P					
		25-48	CL Hori mdbk	fr SS SP SE-P					
2	6% Liber	0-10	SCL wbk	FI SS SP SE-P					PS .3
		10-34	CL mdbk	FI SS SP SE-P					
		34-45	CL Saprolite	FM SS SP SE-P					
3	5% Liber	0-6	SCL	SS SP SE-P					PS .35
		6-16	CL mdbk	SS SP SE-P					
		16-39	SCL/Sap	SS SP SE-P					
		39-48	Sap	NS NP NE-P					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity 36" Rock	Pump 50% Red
Site LTAR	.3	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____