DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: D+D Enterprises APPLICANT: Chris Davidson
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 6/25
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 gal. PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: Y
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #2

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	3% Linear	0-4	scl wsbk	ss sp sep					PS .35
		4-30	cl wsbk	✓ ✓ ✓					
		30-48	cl/sap	✓ ✓ ✓					
2	4% Linear	0-10	scl wsbk	ss sp sep					PS .35
		10-18	cl msbk	✓ ✓ ✓					
		18-38	cl/sp	✓ ✓ ✓					
		38-48	sp	ns np nep					
3	2% Linear	0-6	scl wsbk	ss sp sep					PS .35
		6-19	cl	✓ ✓ ✓					
		19-39	cl/sp	✓ ✓ ✓					
		39-48	sap	ns np nep					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Reduction Gravity	50% Reduction Pump
Site LTAR	.35	.35

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: ___