DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: D+D Enterprises APPLICANT: Same
ADDRESS: Trenton, N.C. APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: 3BR House (Crawl) PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .69
LOCATION OF SITE: ___ PROPERTY RECORDED: Y
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Cottrell Prewitt Rd Estates

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	2% Linear	0-8	sl g	fr VS NP NE xP					PS .3
		8-15	scl wabk	fr/fi SS SP SE xP	18" yel/BRN mottles				
		15-35	cl some mica sbk	fi SS SP SE xP					
		35-48	cl many mica ✓	fi/fr SS SP SE xP					
2	Linear	0-8	sl g	fr NS NP NE xP					PS .3
		8-13	scl/cl wsbk	fr/fi SS SP SE xP	20" 2.5Y 7/2 mottles				
		13-32	cl some mica wsbk	fi SS SP SE xP					
		32-45	cl many mica vwsbk	fr/fi SS SP SE xP					
3	3% Linear	0-9	sl g	fr NS NP NE xP	13-34" Red/yel mottles				PS .3
		9-18	scl wabk	fr/fi SS SP SE xP					
		18-34	cl few mica sbk	fi SS SP SE xP					
		34-48	cl many mica wsbk	fr/fi SS SP SE xP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv.	Pump 50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: ___