IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry C. Waggoner DATE 2/21/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Timber Ridge Subdivision on Rd 1332 from Critchfield Rd S. R. No. _____

SUBDIVISION NAME Timber Ridge LOT NO. 2 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slope to back
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Erskine

IMPROVEMENTS PERMIT BY _____

COMMENTS: Extra fill to be put over shallow place in lines near step down. Well not down at this time Downspouts & surface water to be diverted away. ~~Have to this time.~~

CERTIFICATE OF COMPLETION BY E. A. Stutenson DATE 2/22/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold