IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gene McDaniels DATE 11-16-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Buffalo Shoals Rd. T.L. on Rd 1333. T.R. on Rd # 1422 Last house on left S. R. No. 1422

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____

Character & Porosity of Soil Red Clay
Percolation Rate No Perc Test
Topography Sloping to Back [redacted] Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing House - Surface water should be diverted away from lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-16-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold