IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R.F. Bagwell DATE 4-3-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd to Eufola Rd on Rt, Go across RR, 1st Brick house on left S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area _____

Character & Porosity of Soil Red Clay loam
Percolation Rate good
Topography level
Depth to Water Table —
Rock or other impervious formations —



Size of Tank 1,000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lackey Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: 15' from house to tank, from tank to fence 13', drain lines no closer than 10' from fence

CERTIFICATE OF COMPLETION BY Andrew Carey - William M Tidwell DATE 4-3-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold