DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE-WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Gary Gary Harris APPLICANT: Same
ADDRESS: 237 Kearington Statesville, NC APPLICATION DATE: 4-13-99 DATE EVALUATED: 5-3-99
PROPOSED FACILITY: 3 Bdrm Mod PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2 Ac
LOCATION OF SITE: End of Virgil's Place Rd on right 1/4 Acres off E Lewis Ferry Rd PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	N 10%	0 30	SBK C	FI SS SP SE RO	BRWN				PS
		30 48	SBK C	FI SS P	Yellow Brwn	yellow Rock			.3
2	N 10%	0 28	SBK C	FI SS SP SE RO	BRWN				PS
		28 48	SBK C	FI SS SP	Brwn/Yellow	Rock at 30			.3
3	L 8%	0 48	SBK C	FI SS SP SE RO	BRWN				PS
									.5
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 sqft 4 bdrm	1200 sqft 4 bdrm
System Type(s)	III A Conv	25% Red.
Site LTAR	.3	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): LS
EVALUATED BY: [signature]
OTHER(S) PRESENT: ____