IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Brawley DATE 6-23-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W-T.L. on old Mountain Rd. T. R. on 1368 House on R. Near Enfield. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Existing System
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Area 2 Acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 522 Linear Ft. 225
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

Installed by Hoke in 1969

IMPROVEMENTS PERMIT BY _____

COMMENTS: Plans to use Present sewage system for House. System is Presently working satisfactorily. When house is Completed Trailer will be moved off of lot.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-23-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold