DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

/48548
47/2433435

OWNER: J. PRICE
ADDRESS: 234 LEWIS FERRY RD Smithfield NC 27577
PROPOSED FACILITY: 3 BR HSE
PROPOSED DESIGN FLOW (.1949): 360
LOCATION OF SITE: GO FOR FARMS LOT 3
APPLICATION DATE: _____
DATE EVALUATED: _____
PROPERTY SIZE: _____
PROPERTY RECORDED: YES

WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	scl wk gr	fri non-sx	few mott sec stds @ 48"				PS .3
		4-48	cmd sbk	fri sx					
2		0-4	scl wk gr	fri non-sx	> 4% inclusions < 50% 34-48" yellow/brown sap mat mottles				PS .3
		4-36	cmd sbk	fri sx					
		36-48"	cmd sbk	fri sx					
3		0-8"	scl wk gr	fri non-sx	few yellow/brown sap inclusions < 5% 28-48"				PS .3
		8-48"	cmd sbk	fri sx					
4		0-6"	scl wk gr	fri non-sx					PS .3
		6-48"	cmd sbk	fri sx					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	LPW 25	LPD 50%
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: J. PRICE

COMMENTS: _____