IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 154326 PIN # 4712442997 DATE 1-15-09

OWNER or APPLICANT RICHARD + MELONEY TALLENT PHONE: Business 704-902-4040 Home: 704-528-3410

OWNER or APPLICANT ADDRESS 155 Greycroft Drive Statesville NC 28677

LOCATION / DIRECTIONS 40 WEST (L) OMR (R) BUFFALO SHOALS (R) EUFOLA (R) ATWELL (R) THROUGH AT END OF PT

SUBDIVISION EUFOLA FARMS BLOCK / SECTION LOT # 15 LOT AREA 2.947 DESIGN FLOW 360 L.T.A.R. .125

Septic Tank 1000 Gallons: STB LD12 Date 11-6-08
Pump Tank 1000 Gallons: PT LT Date 11-17-08
Pump Make GOULDS Model WE03111M Serial # B1953841
Nitrification Field No Fields 1 No Lines 4 Linear Feet 360'
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A ☐ GRAVITY ☒ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI
System Description: PUMP 35' FROM CT
Repair System Description: LD 50' FROM CT
Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 3
☐ Business No. Persons 6
☐ Other No. Employees
☐ Slab ☐ Crawl Space
☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions (1) CALL Prior to installation for pump sizing + system specs if necessary (2) MAINTAIN SETBACKS

Comments / Conditions POWERLOCK Filter + MANIFOLD
System is 10'+ OFF PROPOSED P/L ATTENOS; Pressure manifold is 34' OFF PROPOSED P/L.

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LAURIE COX, R.S.I.

AS BUILT SKETCH

Location of the proposed POOL addition does not appear to impact the existing on-site septic system.**NOTE:

REHS

Date: 1-2-12

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ IMPROVEMENT PERMIT w / plat valid without expiration. ☒ IMPROVEMENT PERMIT w / site plan valid for 60 mos. ☐ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.

Owner / Applicant Signature: Date 1-15-09

Improvement Permit by: Date 1-15-09

Authorization to Construct by: Date 1-15-09

Installed by: Craig Thompson Grading 1179

Operation Permit by: Date: 5-26-09

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant