IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert J. Hoke DATE 3-8-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 To old Mt. Rd. T.L. T.R. on Eufola Rd # 1368 S. R. No. _____
Go appox 1 mile. House off Rd on L.

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Acreage

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

Existing Septim



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
Installed in 1968

Installed by Robert Hoke

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trailer will be moved when house is Completed.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-8-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold