DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY RECORDED: _____

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Steven Lambeth OWNER: _ AGENT: _ PHONE: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: _____

PROPERTY SIZE: _____

LOCATION OF SITE: _____

WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 3%	0 to 4	L GR		PS	PS	PS	PS	.3
		4 to 48	C SBK	SEAP Fi					
2	linear 3%	0 to 4	L GR		PS	PS	PS	PS	.3
		4 to 46	C SBK	SEAP Fi					
3	linear 4%	0 to 4	L GR		2 Chroma 2	U	U		
		4 to 30	C SBK	SEAP Fi					
		30 to 40	C ABK	EAP Fi					
4									
5									

AVAILABLE SPACE (.1945): yes SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: _____ OTHER(S) PRESENT: _____

COMMENTS: _____

0011159