HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Tindell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tim Campbell OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 5-6-94
PROPOSED FACILITY: 4 Bedroom MH (Double wide)
PROPERTY SIZE:
LOCATION OF SITE: Eufola Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	3-5% L	0-7"	l	gr	1:1 / vfr	.1942 WETNES CONDITION	- S
		7"-25"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	- U 25"-32"
		25"-32"	saprolite			.1944 RESTRICTIVE HORIZON	- 32" to Rock
		32"	rock			.1948 PROFILE CLASSIFICATION	- P.S.
						PROFILE LTAR	- .35
2	3-5% L	0-7"	l	gr	1:1 / vfr	.1942 WETNES CONDITION	- S
		7"-15"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	- U 15"-34"
		15"-34"	saprolite			.1944 RESTRICTIVE HORIZON	- S
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
3	4-6% L	0-5"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	- S
		5"-29"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	- U
		29"-42"	saprolite			.1944 RESTRICTIVE HORIZON	- S
						.1948 PROFILE CLASSIFICATION	- P.S.
						PROFILE LTAR	- .3
4	4-6% L	0-6"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	- S
		6"-32"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	- U 32"-47"
		32"-47"	saprolite			.1944 RESTRICTIVE HORIZON	- S
						.1948 PROFILE CLASSIFICATION	- P.S.
						PROFILE LTAR	- .35
5	2-3% L	0-4"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	- S
		4"-30"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	- U 30"-34"
		30"-34"	saprolite			.1944 RESTRICTIVE HORIZON	- PS 34"-↑ Rock
		34"	rock			.1948 PROFILE CLASSIFICATION	- P.S.
						PROFILE LTAR	- .35

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .3 gpd/ft²
OTHER FACTORS (.1946) SYSTEM TYPE
EVALUATED BY: Michael D. Evans OTHER(S) PRESENT: Tim Campbell
COMMENTS: All auger holes (evaluations) that are P.S. are P.S. for LPP system. Saprolite may be reclassified if evaluated with backhoe.
Improvement Permit denied unless LPP. system permited or Saprolite evaluated with Backhoe.

DRAFT