HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sunwood Builders OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: lot 21 woodland acres
LOCATION OF SITE: ____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	Linear 8%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 42	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		42 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear 8%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 40	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		40 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
3	Linear	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE - 42"
		36 to 42	Transition			.1944 RESTRICTIVE HORIZON - N/A
		42 to 48	Saprolite			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) ____ SYSTEM TYPE Conv. - Curtain
EVALUATED BY: R.C. Moore OTHER(S) PRESENT: David Stikeleather
COMMENTS: ____

DRAFT