DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sun-Wood Bldrs. OWNER (IF DIFFERENT FROM APPLICANT):
ADDRESS: APPLICATION DATE: 3-3-94
PROPOSED FACILITY: 3 Bedroom DW M/H
PROPERTY ID:
LOCATION OF SITE: Woodland Acres Lot #23
WATER SUPPLY: On-Site Well ✓ Community Well ___ Public ___ Other ___ EVAL METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1940 LANDSCAPE POSITION	HORIZON DEPTH (IN.)	TEXT.	STRUCT.	CONSIST.	
1	3-5% N	0-3"	cl	gr	1:1 / vfr	P.S.
		3"-48"	C	sbk	1:1 / fr	NA
						NA
						P.S.
						.35
2	3-5% N	0-7"	scl	gr	1:1 / vfr	P.S
		7"-43"	SC	sbk	1:1 / fr	43"-↑
		43"-↑	Saprolite			NA
						P.S
						.35
3	4-6% N	0-7"	cl	gr	1:1 / vfr	P.S.
		7"-45"	C	sbk	1:1 / fr	45"-↑
		45"-↑	Saprolite			NA
						P.S
						.35
4						
5						

PROFILE #	1940 WETNESS CONDITION	1940/1956 SAPROLITE	1956 RESTRICTIVE HORIZON	1956 PROFILE CLASSIFICATION	PROFILE LOAD
1	-	-	-	-	-
2	-	-	-	-	-
3	-	-	-	-	-
4	-	-	-	-	-
5	-	-	-	-	-

AVAILABLE SPACE (1949): P.S. SITE CLASSIFICATION (1956): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS: SYSTEM TYPE:
EVALUATED BY: Michael J. Dennis PERSON(S) PRESENT: Perry Jenkins
COMMENTS:

DRAFT