DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: ____
DATE: ____
COUNTY: ____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Sunwood Builders OWNER__ AGENT:__ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 19 wood Land acres
WATER SUPPLY: On-site Well / Comm. Well__ Public__ Other____ EVAL. METHOD: Auger Boring / Pit__ Cut__

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1 Linear	4 to 10	0 to 6"	L	GR				.1942 Wetness Cond. - N/A
		6 to 48	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	6 to 10							.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
2 Linear	4 to 10	0 to 6"	L	GR				.1942 Wetness Cond. - N/A
		6 to 48	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	6 to 10							.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
3 Nose Slope	4 to 10	0 to 6"	L	GR				.1942 Wetness Cond. - N/A
		6 to 48	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	6 to 10							.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Yes OTHER FACTORS (.1946) ____ SITE CLASSIFICATION (.1948) PS
SYSTEM TYPE Conv Gravity LONG-TERM ACCEPTANCE RATE(S) .35
EVALUATED BY: P. C. Moore OTHER(S) PRESENT: mike Hogan
COMMENTS: ____