DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sun-wood Builders OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: 125 X 250 Acres
LOCATION OF SITE: Lot 32 woodland
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINERALOGY	
1	Linear 10%	0 to 4"	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 24	C	ABK	1:1	.1943/.1956 SAPROLITE - 36"
		24 to 36"	Transition			.1944 RESTRICTIVE HORIZON - N/A
		36" +	Saprolite			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Linear 10%	0 to 4"	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 30	C	ABK	1:1	.1943/.1956 SAPROLITE - 36"
		30 to 36"	Transition			.1944 RESTRICTIVE HORIZON - N/A
		36"+	Saprolite			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	Linear 10%	0 to 4"	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE - 36 N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: J.C. moore OTHER(S) PRESENT: mike Dennis David stikeleather
COMMENTS: _____

DRAFT