HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sunwood Builders OWNER: __ AGENT: __ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ~~1.95~~ 1.8 acres
LOCATION OF SITE: Lot 31 Woodland acres
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	15% linear	0 to 4 11	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	15% linear	0 to 4 11	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 36 11	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) ____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: D.C. Moore OTHER(S) PRESENT: Tommy Cathren (Dug Pits)
COMMENTS: David Stivel Cathren

DRAFT

U2362