DIVISION OF ENVIRONMENTAL HEALTH
WASTEWATER SECTION

PROPERTY ADDRESS
COUNTY Iredell

# SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT Sun-Wood Bldrs. OWNER ACRES
ADDRESS PHONE
PARCEL ID NO. 3 Bedroom D.W. M/H DATE 11-1-94
PROPOSED FACILITY
LOCATION OF SITE Lot #25 section II Woodland Acres
WATER SUPPLY On-Site Well ✓ PUBLIC PUBLIC WELL PROPERTY LINES ✓

| SOIL GROUP | LANDSCAPE POS. SLOPE % | HORIZON DEPTH IN | TEXT | STRUCT | CONSIS | |
|---|---|---|---|---|---|---|
| | | 0-5" | cl | gr | fr | S |
| | | 5"-37" | c | Abk | fi | NA |
| | | 37"+ | Rock | | | 37" Rock |
| | | | | | | PS. |
| | | | | | | .3 |
| | | 0-7" | cl | gr | fr | S |
| | | 7"-40" | c | Abk | fi | 43" P.S |
| | | 40"-43" | c/sap | Abk/m | fi | NA |
| | | 43"+ | sap | m | fr | P.S |
| | | | | | | .3 |
| | | 0-5" | cl | gr | fr | S |
| | | 5"-30" | c | Abk | fi | 38" P.S |
| | | 30"-38" | c/sap | Abk/m | fi | NA |
| | | 38"+ | sap | m | fr | P.S |
| | | | | | | .3 |
| | | 0-4" | cl | gr | fr | S |
| | | 4"-31" | c | Abk | fi | 37" P.S |
| | | 31"-37" | c/sap | Abk/m | fr | NA |
| | | 37"+ | sap. | m | fr | P.S |
| | | | | | | .3 |
| | | | | | | |

USABLE SPACE (1945) S SITE CLASS (1945) P.S. SOIL/LANDSCAPE LTAR .3 gpd/ft²
CORRECTION FACTORS (1945) SYSTEM TYPE conventional, gravity fed
EVALUATED BY Michael J. Dennis Tommy Cothren, David Stikeleather
NOTES

DRAFT

0237 6