HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sun-Wood Bldrs OWNER: _ AGENT: _ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7-31-95
PROPOSED FACILITY: 3Bedroom DW MH
PROPERTY SIZE: 8.73 acres

LOCATION OF SITE: Woodland acres Lot #29
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1 Pit	6-8% L	0-3"	l	gr	1:1 / fi	.1942 WETNESS CONDITION - S
		3"-48"	c	wsbk	1:1 / fi	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
2 Pit	6-8% L	0-4"	l	gr	1:1 / fi	.1942 WETNESS CONDITION - S
		4"-48"	c	wsbk	1:1 / fi	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
3 Pit	6-8% L	0-3"	l	gr	1:1 / fi	.1942 WETNESS CONDITION - S
		3"-30"	c	wsbk	1:1 / fi	.1943/.1956 SAPROLITE - P.S. @ 39"
		30"-39"	c/sap.	wsbk/m	1:1 / fi	.1944 RESTRICTIVE HORIZON - NA
		39"-48"	Sap.	m	fi	.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
4 Auger	6-8% L	0-4"	l	gr	1:1 / fi	.1942 WETNESS CONDITION - S
		4"-48"	c	wsbk	1:1 / fi	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): P-S. SITE LONG-TERM ACCEPTANCE RATE: .32 gpd/ft2
OTHER FACTORS(.1946) _____ SYSTEM TYPE conventional gravity fed
EVALUATED BY: Michael Dunston OTHER(S) PRESENT: Brad Shellard, Rory Jenkins, Tommy Cathren
COMMENTS: Footings for DW MH complete at time of evaluation.

DRAFT

0019401