HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jerry W Price OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-8-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1945 LANDSCP POS SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	3-5% L	0-3"	scl	gr	1:1 / vfr	1942 WETNESS CONDITION	PS
		3"-20"	sc	sbk	1:1 / fr	1943/1956 SAPROLITE	20"-↑
		20"-↑	Saprolite			1944 RESTRICTIVE HORIZON	NA
						1945 PROFILE CLASSIFICATION	LI
						PROFILE LTAR	
2	2-4% R	0-4"	scl	gr	1:1 / vfr	1942 WETNESS CONDITION	P.S.
		4"-36"	sc	sbk	1:1 / fr	1943/1956 SAPROLITE	36"-↑
		36"-↑	Saprolite			1944 RESTRICTIVE HORIZON	NA
						1945 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	2-4% R	0-5"	scl	gr	1:1 / vfr	1942 WETNESS CONDITION	P.S.
		5"-37"	sc	sbk	1:1 / fr	1943/1956 SAPROLITE	37"-↑
		37"-↑	Saprolite			1944 RESTRICTIVE HORIZON	NA
						1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4	3-5% L	0-4"	cl	gr	1:1 / vfr	1942 WETNESS CONDITION	P.S
		4"-44"	C	sbk	1:1 / fr	1943/1956 SAPROLITE	NA
						1944 RESTRICTIVE HORIZON	NA
						1945 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
5	3-5% L	0-5"	cl	gr	1:1 / vfr	1942 WETNESS CONDITION	P.S.
		5"-40"	C	sbk	1:1 / fr	1943/1956 SAPROLITE	40"-↑
		40"-↑	Saprolite			1944 RESTRICTIVE HORIZON	NA
						1945 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35

AVAILABLE SPACE (.1945): P.S. SITE CLASSIFICATION (.1946): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946): SYSTEM TYPE: Conventional, gravity fed.
EVALUATED BY: Michael L. Dennis OTHER(S) PRESENT: Jerry Price.
COMMENTS:

DRAFT