**IREDELL COUNTY HEALTH DEPARTMENT**

County Building | Phone 1164 | Statesville, N. C.

**PERMIT TO INSTALL SEPTIC TANK**

Permit No. 1066 Permit Date 11-17 1948

Owner Paul White Address Duck Rd.

Tenant ____ Address Statesville Rt 6

Installed by Mundy Address Draftsman

Location of Property Duck Rd.

Kind of Tank C. Block Capacity 1000 Length of trench ____


**NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED**

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 8-17 1948 Approved ✓ Disapproved ( )

Remarks: ____

First five feet of line from outlet should be of cast iron soil pipe.




Chas. A. Beatty
Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.