DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: _____
COUNTY: Yadkin
471314 7886

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BEN PRICE APPLICANT: SAME
ADDRESS: 239 LEWIS FERRY RD APPLICATION DATE: 12/11/00 DATE EVALUATED: 01-17-01
PROPOSED FACILITY: ONE MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 6.87 ACRE
LOCATION OF SITE: LEWIS FERRY RD 3/4 mile on left PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut (X) SYSTEM STAKED FOR 3BR
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed NEED PITS

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	13% Linear	0-3	scl, wk, gr	fr, ns, np, exp	24" mottled	>48"			P .5
		3-24"	c, mod, sbk	fi, ss, p, exp					
		24-48"	c, mod, sbk	fr, ss, p, exp					
2	18% Linear	0-3"	scl, wk, gr	fr, ns, np, exp		>48"			PS .35
		3-24"	c, mod, sbk	fi, ss, p, exp					
		24-48"	c, sap, mix	fr, ss, p, exp					
3	18% Linear	0-3"	scl, wk, gr	fr, ns, np, exp		≤ 24"			US PITS
		3-24"	c, mod, sbk	fi, ss, p, exp					
		24-48"	APPALTH						
4	18% Linear	0-3"	scl, wk, gr	fr, ns, np, exp	24" mottled	>48"			P .5
		3-24"	cl, mod, sbk	fr, ss, p, exp					
		24-48"	c, mod, sbk	fr, ss, p, exp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	NO	NO
System Type(s)	NA	NA
Site LTAR	US	US

OTHER FACTORS (.1946): MOST HAVE PITS
SITE CLASSIFICATION (.1948): US
EVALUATED BY: L COOK
OTHER(S) PRESENT: BEN PRICE / JEFF PRICE