IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Heintz DATE 10- PERMIT NO.

PHONE: Business Home

LOCATION Hwy 64-70 W. House on L. 3rd house Before you get to White Oak. S. R. No.


SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	No Perk Test Made	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Sloping to Front	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low	
			Rock or other impervious formations	None	

Lot Area 2 3/4 acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 637½ Linear Ft. 255
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Lackey Bro.

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS:

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 10-31-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold