Septic TANK

22' off the Rear Foundation

16' off the R side of foundation

Drain Lines are 6'-8' apart

Location of the proposed Garage Pad 30x35 addition does not appear to impact the existing on-site septic system.**NOTE:

Date: 7-9-2013 REHS

ICHD-Environmental Health Division