IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Shirley Johnson DATE 8-1-77 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 64-70 W. to White Oak. T.L. on old Mt. Rd. T.R. on Eufola I.P.C. #1368 - Trailer on Rt. just beyond 1st house

SUBDIVISION NAME _____ LOT NO. _____ S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prov. Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope to Road
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
Lot Area Acreage			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8/1/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold