IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# D89331 PIN# 4736 3248 (lot) 4713-53-9436 DATE July 26, 01

OWNER OR CONTRACTOR Earl Garwick PHONE: Business Home

ADDRESS 9815 J Sam Furr Rd. Huntersville NC 28078

LOCATION From Trantman old Mtn Rd TL Angel Oaks Dr. TR Falling Leaf TL Turning Leaf JR Peyton Ct. 1st on lt

SUBDIVISION Angel Oaks BLOCK / SECTION LOT 36/36A LOT AREA 1.11ac +.42ac (SCE) SITE CLASS PS SCE DESIGN FLOW 360 gpd LTAR .3 (SCE)

Septic Tank: 1000 Gallons. STB 1072 Date 7-10-01

Pump Tank: 1000 Gallons. PT 17 Date 6-18-01

Pump Make: Hydromatic Model SHEPSA1 Serial No 57867-008

Trenches: No Fields 1 Square Feet 400/400 Linear Feet 200

No Lines 6 Trench Width 24" min Max Max Trench Bottom Depth 36" Gravel Depth N/A

✓ New System Repair System Type I II @ N V VI

System Description PP DPC

Repair System Description LPP TBPS

Maintenance Agreement Required Yes No initially

House/Mod Home No Bedrooms 3

Mobile Home No Bathrooms 2

Business No Employees

Other

Slab Crawl Space Basement w/plumbing Basement w/o plumbing

Water Supply: Individual Public Community

Comments/Conditions: CK #HARVEL

Comments Conditions FINAL GRADING NEEDS TO BE COMPLETED
6-4 OP IS ISSUED 1.96 Risers installed
Liner + Tank OKay 10/31/01 ; Pressure Check okay
Elec + Alarm Okay 11/2/01

INITIAL SITE SKETCH 1"=40'

AS BUILT SKETCH

The proposed Pool AND BLDG addition does not appear to impact the existing septic system.

**NOTE:

R.S.

Date: 8-10-01

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site any unauthorized changes are made in the installation of the system. Improvement Permit with plot valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit -- not to exceed sixty months.

Issued: date 7-27-01 Installed by: A-1 Backhoe

Improvement Permit by: date 7-26-01 Operation Permit by: date 11/13/01

Authorization to Construct by: date 8-13-01 Existing System Inspection by date

HEALTH DEPT COPY WHITE OWNER COPY (FINAL) YELLOW OWNER COPY (INITIAL) PINK

JAN. 25, 1989 13:15