DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BILLY RAY DISHMAN APPLICANT: STEVE LIPE (FLEETWOOD)
ADDRESS: _____ APPLICATION DATE: 1-4-01 DATE EVALUATED: 1-25-01
PROPOSED FACILITY: 3 BR PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1 AC
LOCATION OF SITE: OLD MTN. RD. PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	LSS	0-3	SL VWSBK	VF, NS NP	>48"	>48"		N/A	PS .3
		3-24	C WSBK	Fr SS SP					
		24-40	SC WSBK	Fr SS SP					
		40-48	C/SAP F/C						
2	LSS	0-8	SCL	VF, NS NP	>48"	>48"		N/A	PS .35
		8-12	SC	Fr SS SP					
		12-42	C	Fr-Fi SS SP					
		42-48	C/SAP(w) P/C						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	II
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: T. SHINN
OTHER(S) PRESENT: STEVE LIPE