13172.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DARREN SWAIN DATE 7-30-91. PERMIT NO. 8V-8-A-24.

PHONE: Business _____ Home _____

LOCATION Bethlehem Rd. off old Mtn. Rd. - go 1/4 mi. FT. L. into dev. - go 250 yards on left. S. R. No. _____

SUBDIVISION NAME MTN. ROAD VILLAGE. LOT NO. 24. SECTION OR BLOCK NO. _____

House ( ) Mobile Home (DOUBLEWIDE.) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (4)	
Auto. Dishwasher	Yes (4)	No ( )	
Auto. Wash. Machine	Yes (4)	No ( )	
Site Suitable	Yes (4)	No ( )	

Character & Porosity of Soil Prov. Suitable.
Percolation Rate 4 gal/sq. ft.
Topography 2-8%
Depth to Water Table 18+
Rock or other impervious formations none observed.

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12

Water Supply: Individual ( )
Public (4)

Installed by Wayne Eller

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-30-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold