09496

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RICK McKEE DATE 2-2-89 PERMIT NO. 14A

PHONE: Business _____ Home _____

LOCATION Hwy 64-70W-T.L. at White Oaks-T.L. on Bethlehem Pl. Go 1.1 mi. from Nebo Fire Dept.) - ½ mi. on left. S. R. No. _____

SUBDIVISION NAME MT. ROAD VILLAGE LOT NO. 3 SECTION OR BLOCK NO. _____

DOUBLEWIDE


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 125' X 200'

Character & Porosity of Soil Sandy Loam Suitable.
Percolation Rate 2-30 MPI
Topography 2-6%
Depth to Water Table 10+
Rock or other impervious formations None Observed.

_____ Basement with Plumbing STREET _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Lineal Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Coffin Farms.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Lisa Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Lisa Brown DATE 2-27-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold