DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Sabrina Stroud APPLICANT: Same
ADDRESS: Statesville N.C. APPLICATION DATE: _____ DATE EVALUATED: 7/16/01
PROPOSED FACILITY: 3BR MH/D PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	7% Linear	0-14	SaSL sbk	fr. SS SP SEXP	10YR 5/6				PS .3
		14-32	cl sbk	fi SS SP SEXP					
		32-48	cl sbk	fi SEXP					
2	Linear	0-15	Bcl	Fi SS SP SEXP					LS
		15-24	cl w/ s.	fi SS SP SEXP					
		24"	Rock						
3	7%	0-16	cl sbk	Fr SS SP SEXP					PS .3
		16-23	cl	Fi Fr SS SP SEXP					
		23-35	cl sap sbk	Fr SS SP SEXP					
		35-48	sap	Fr SS SP SEXP					
4	8%	0-3	cl	Fr SS SP SEXP	10YR 5/8				PS .3
		3-18	cl varies sbk	Fr SS SP SEXP					
		18-38	cl sap	Fr SS SP SEXP					
		38-48	sap	Fr SS SP SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. 25% Reduction	Pump to Surface
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____