45269

15342

# IREDELL COUNTY HEALTH DEPARTMENT

## IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR VIRGINIA G. STEPHENS DATE 11/10/92 PERMIT NO. 8K-8-A-29

PHONE: Business _____ Home _____

LOCATION I-40 W, TL OLD MOUNTAIN ROAD, TL BETHLEHEM ROAD (SR 1363), TL 1ST PAVED LT (SR 2744), LAST LOT ON (L) BEFORE CUL-DE-SAC S.R. NO.

SUBDIVISION NAME MOUNTAIN ROAD VILLAGE LOT NO. 29 SECTION OR BLOCK NO. _____


House ☐ Mobile Home ☑ D/W Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ☐ | No ☑ | Soil Characteristics | PS |
| Auto. Dishwasher | Yes ☑ | No ☐ | Application Rate | 0.40 GPD / FT2 |
| Auto. Wash. Machine | Yes ☑ | No ☐ | Topography | 6-10% |
| Lot Area 125' X 200' | | | Depth to Water Table | >4' |
| | | | Rock or other impervious formations | SOME SURFACE ROCK AT BACK OF LOT |

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space

CUL-DE-SAC




Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑

Installed by A-1 BACKHOE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE BROWN

COMMENTS REPAIR AREA IS 100% CONVENTIONAL, GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 11/10/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

BETHLEHEM ROAD