Not on Computer

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

14185

OWNER OR CONTRACTOR MARTY TOLLEY DATE 3/6/92 PERMIT NO. BK-8-A-32

PHONE: Business _____ Home _____

LOCATION I 40 W, TL OLD MTN RD, TL BETHLEHEM RD, TL MTN ROAD VILLAGE, STRAIGHT TO END OF CUL-DE-SAC S. R. No. _____

SUBDIVISION NAME MTN. ROAD VILLAGE LOT NO. 32 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area AMPLE

Character & Porosity of Soil PS
Percolation Rate .46 GPD /FT²
Topography 4-6%
Depth to Water Table >4'
Rock or other impervious formations SURFACE SMALL ROCK

TP 12/10/92

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by JOHN MEUSCER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE BROWN

COMMENTS: ① REPAIR AREA IS CONVENTIONAL GRAVITY FED WITH ~0.4 GPD/FT² APPLICATION RATE. ② MH NOT ON SITE AT TIME OF INSPECTION, KEEP MH MINIMUM 5' FROM SYSTEM. ③ SYSTEM INSTALLED DURING PERIOD OF HEAVY RAIN.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 3/6/92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold