IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Trinity Baptist Church DATE 7/18/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. Tyr. on old Mountain Rd. Church on Rt. approx ¼ Mile beyond Celeste Henkel School S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms _____ No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	
Site Suitable	Yes ( )	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ✓
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water should be diverted away from septic tank & lines. No kitchen facilities at this time

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7/18/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold