IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Watts DATE 5/14/79 PERMIT NO.

PHONE: Business Home

LOCATION Hwy. 64-70 W. T.L. on old Mountain Rd. Go aProx ½ mile Past Celeste Henkel School. T.L. House on L. Near End S. R. No.

SUBDIVISION NAME Celeste Estates LOT NO. 21 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2 Acres

Character & Porosity of Soil Prof Suitable
Percolation Rate
Topography 2-6% Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tanks

IMPROVEMENTS PERMIT BY

COMMENTS: Divert all surface water away from septic Tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5/14/79

CONSTRUCTION MUST COMPLY WITH ALL OTHEI

The location of the proposed Bathroom Addition addition does not appear to impact the existing septic system.
**NOTE:

REHS
Date: Dec 16, 2010
ICHD-Environmental Health Division

Health Dept. Copy: White Inspection Dept. Copy: Yell