HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Vincent Belton OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-4-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public ✓ Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	3-5% L	0"-8"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION	PS.
		8"-48"	C	Sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	2-3% L	0"-10"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION	PS
		10"-48"	C	Sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	3-5% L	0"-7"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION	PS.
		7"-48"	C	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	PS.
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: Michael J. Dennis OTHER(S) PRESENT:
COMMENTS:

DRAFT